



Missouri Department of Natural Resources

Clean Water Information System

Event Search

[Overflow / Bypass Event Details](#)

[Initial Report](#)

Facility Name: Bolivar WWTF

Permit No: MO0022373

*** Indicates a Required Field**

****Indicates a Required Field for Final Report**

Once you enter the Event End Date & Time fields and Add Event/Save Changes, you will no longer be able to

Event Details

Bypass = at the wastewater treatment plant; Overflow = in the collection system

Confirmation No: 1992

*Type of Event: SSO (Overflow)

*Wet or Dry Event? Dry

*Event Begin Date: 03/29/2013 (MM/DD/YYYY)

*Event Begin Time: 09:15 (HH:MM) Military Time

**Event End Date: 03/29/2013 (MM/DD/YYYY)

**Event End Time: 10:00 (HH:MM) Military Time

Event Duration (hh:mm) 0d:0h:45m:

*Initial Report Date: 03/29/2013 (MM/DD/YYYY)

*Initial Report Time: 10:44 (HH:MM) Military Time

Discharged To: Ground

*Reported By: James

*Immediate Contact (417) 777 - 0981

Ongoing?: ☐

*Estimated Volume at time of Initial Report (gallons): 800.00

Is bypass/overflow reaching Waters of the State? ☐

Effected Waterbody:

**Cause of Event: Power Outage

Cause of Event Comments:

Lost power to the lift station could not shut the valve because of a car park on it. Power came back on before tow truck show up. life station #3

Event Type:

* To select more than one choice hold down the control key o

Additional Impact:

Location Information

County

UTM Easting:

UTM Northing:

* Location Description


Double click on the map to zoom in. The mouse wheel or the slider may be used to zoom in or out. Use the pan buttons o to another location. Select a county from the drop down to zoom to that county.

County:

Scale 1:2,400

☒ Flag Icon

Select the red indicator to activate the marking tool then single click on the map to mark the location of yo





5 - Day Report

****Estimated Final Total Volume (gallons):**

Did bypass reach Waters of the State? ☐

****Response:** we are going to look about getting a portable generator and putting stop blocks around the valve so it does not get parked on again. sso stop when power come back on and the lift station



Missouri
Department of
Natural Resources

1-800-361-4827 / 573-751-1300
E-mail: cleanwater@dnr.mo.gov